شركة بشائر البناء للمقاولات
Bashaer Al-Benaa Contracting Company

ECEC شركة السرى

SAUDI الهيئة السعودية TOURISM AUTHORITY للسياحة

Site:	FITOUT PROJECT AL-RAED RIYADH	WIR -Area- Bldg site - Disc	REQUEST No.	150	Rev.# Of Copies	1
			Serial	BBC-ECE-AR-WIR-15-R01	
To:	CONSULTANT	Date:	9/1/2023		

WORK INSPECTION REQUEST

We hereby request the Engineer's attendance to inspect the following work:

Level of Inspection: ☐ Hold ☐ Witness ☑ Release Inspection ☐ Handing Over

Location of Inspection: GR Floor

Reference Documents and Attachments:

Specification #: ☐ **MIR #:** ☐ **Inspection Checklist #:** ☐ **Certificate:** ☐

Clearance & Releases: ☐ **Marked-up Approved Shop Drawings:** ☐

Activity ID BOQ.: **Date & Time of Inspection:** 10/1/2023

Previous Inspection History:

Meeting Notes #: **Testing Results:** **Issued NCR #:**

Description of Work:	**1st Layer of block works for GR Floor in Data Room "SIZE 25 CM"** AS PER HIGHLIGHTED Drawing
Contractor's QC Report:	**works conforms to specifications**

We certify that the submitted work for inspection has been executed in accordance with the contract's specification and approved shop drawings.

PM. Name: Eng.AHMED MEDHAT **Signature:** **Date:**

Surveyor: Eng.Sabry **Signature:** **Date:**

DC. Name: Ahmed ABDULKARIM **Signature:** **Date:**

Engineer's Inspection Comment:

* dimension of dwg (attached) & as per actual site not same, should rectify before start work as Per instruction
* Should attached approved S.D, any conflict arise in site work, contractor should be responsible

Inspection Status:

A - Approved / Proceed ☐ B - Approved with comments ☑ C - Rejected ☐

Name: AMIR KHAN **Signature:** **Date:** 10/1/23.

STA PM:

Name: **Signature:** **Date:** 1-01-2023

Client Representative:

Name: **Signature:** **Date:** 10-1-23

Contractor's Received:

Received by: **Signature:**

Acceptance of the request does not relieve the contractor from full compliance with the requirements of the contract's documents, dimensions selecting fabrication processes and techniques of construction, coordinating his work with that of other trades, and performing his work in a safe and satisfactory manner and correlating all quantities and conformance with the design concept of the project and general compliance with the information given in the contract documents

All requests must be submitted at least 24 hours prior to the required inspection and approval.

CC: ☐ AM QA QC ☐

Area:

Site:

Discipline:

10/1/2023

10/1/23